



Electronic Modular Services Limited

Technology House
Sea Street
Herne Bay
Kent CT6 8JZ

t: +44 (0) 1227 369570
f: +44 (0) 1227 369679
e: enquiries@emsgroup.co.uk

www.emsgroup.co.uk

EC Declaration of Conformity

SmartCell Manual Call Point-

SC-51-0100-0000-XX
SC-52-0200-0000-XX

I declare under our sole responsibility that the above products conform to the essential requirements and other relevant requirements of the following Directives/Regulations and harmonised standards:

Directives/ Regulations	Relevant Harmonized Standards
Radio Equipment Directive 2014/53/EU	EN 62368:2014+A11:2017 ETSI EN 300 220-2 V3.1.1 :2017 ETSI EN 301 489-1 V2.2.0 (2017-03) ETSI EN 301 489-3 V2.1.1 (2017-03) EN 50130-4:2011 EN 62369-1:2009
Construction products Regulation EU No. 305/2011	EN 54-11:2001 + A1:2005 EN 54-25: 2008
RoHS Directive 2011/65/EU	Internal process controls
Marking Directive 93/68/EEC	No applicable standards

Test Report Numbers:

1035-EMS-2018, 101317801-011, 101317801LHD-001A, 101317801LHD-001P
101317801LHD-001G, 10353816LHD-001 and 103589057MKS-001

Signed by:

Date: 27 July 2020

Name: Daniel Griffin

Position: Director of Test & Compliance



A member of EMS Security Group Limited
Company Registered in England & Wales 917296 - address as above
VAT Group Reg No: GB 572 0384 49



Annex A

Products

SmartCell Fire Manual Call Point
SmartCell Information Manual Call Point

SC-51-0100
SC-52-0200

Branding and future variants

The part number consists of an alphanumeric string of text as set out below;

XX-YY-ZZZZ-BBBB-CC

N.B. The last four characters 'BBBB' are allocated for 3rd party branding

The sections of the part number have the following designations;

Product Family:	X
Product Line:	X
Group:	Y
Type:	Y
Power:	Z
Colour:	Z
Indication:	Z
Variant:	Z
Branding	B
Branding	B
Branding	B
Branding	B
Country Code	C * See UTC Country Codes in Appendix C
Country Code	C

Software

Release version 2.04

This software is not updateable remotely devices would need to be returned to the manufacturer

Photograph of product



Limitations

Indoor use only